AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client: Tarkett Australia Pty Ltd

Suite 1 Level 3 3 Columbia Court Baulkam Hills NSW 2153 **Test Number** : 18-003956 **Issue Date** : 9/08/2018

Print Date : 10/08/2018

Sample Description

Clients Ref : "Arbor"

Patterned loop pile carpet plank

Nominal Composition: 100% Solution Dyed Nylon Nominal Mass per Unit Area/Density: Approx. 4kg/m2

Nominal Thickness: Approx. 3.5mm

AS/ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival 12/07/2018 **Date Tested** 08/08/2018 CHF Value 1 2 3 Mean Length 46 5.1 4.3 kW/m² Width 7.6 kW/m² HF-30 Value 2 3 Mean Length kW/m² 4.4 Width kW/m² Smoke Value 2 3 1 Mean Length 206 241 218 208 %.min Width 173 %.min Melting Yes

138714 29195 Page 1 of 2

Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Penetration of flame through to substrate

Accredited for compliance with ISO/IEC 17025 - Testing - Chemical Testing

- Mechanical Testing

- Performance & Approvals Testing

: Accreditation No.

: Accreditation No. 985

983

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



MICHAEL A. JACKSON B.Sc.(Hons)

Yes

APPROVED SIGNATORY

AWTA Product Testing

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client: Tarkett Australia Pty Ltd

> Suite 1 Level 3 3 Columbia Court Baulkam Hills NSW 2153

> > hazard of the product in use.

18-003956 Test Number :

Issue Date

Print Date 10/08/2018

9/08/2018

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

HF30 not reported as flame out time occurred before 30 minutes.

138714 29195 Page 2 of 2

Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing - Chemical Testing

Mechanical Testing

Performance & Approvals Testing

: Accreditation No

Accreditation No · Accreditation No. 1356

983

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.





0204/11/06

APPROVED SIGNATORY