

Certificate

Tarkett Indoor Air Quality Platinum



Linowall

Products / Product Group

Tarkett S.p.A., Via S. Anna 6, 05035 Narni Scalo, Italy

Manufacturer

The products have undergone a successful testing and evaluation program as specified for Tarkett Indoor Air Quality Platinum certification version 3.0 (2016). This includes a chamber test of emissions and aldehydes and a surveillance of the manufacturing site according to DIN 18200, performed by Eurofins as independent third-party certifier and testing lab.

Evaluation of the results from emission testing and inspection:

- ✓ Formaldehyde was below or equal to the limit value of 10 µg/m³ after 28 days.
- ✓ Sum of VOC (TVOC) was below or equal to the limit values of 10 µg/m³ after 28 days.
- ✓ Sum of SVOC was below or equal to the limit value of 10 µg/m³ after 28 days.
- ✓ Quality management system and factory production control program at the production site are capable to ensure a continuous production of very low emitting products.
- ✓ Therefore the product qualifies for the Indoor Air Quality Tarkett Platinum label.

Certificate No.: TIAQP-30-01-09-2017
Date: 1 February 2018
Validity of certificate: 1 February 2023, with annual surveillance and retesting

Third-party certification and testing performed by:

**Eurofins Certification Body VOC
Am Neuländer Gewerbepark 4
21079 Hamburg, Germany**

Head of the Certification Body

Sampling, testing and evaluation were performed according to the standards CEN/TS 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, EN 13419 each in the latest versions.