

# APPROVAL

## FOR ESD PROTECTIVE PRODUCTS ACCORDING TO IEC 61340

This edition (Rev. 1) replaces previous edition. Holder of approval address has been added and the type designation has been changed.

### Validity of the approval

Until 2018-11-23.

### Holder of the approval

Tarkett S.p.A.  
Via S. Anna 6  
05036 Narni Scalo, Terni  
Italy

### Category of product

Floors and floor coverings

### Products

Manufacturer/ supplier	Type designation	Description
Tarkett S.p.A.	Linoleum Conductive xf <sup>2</sup>	Linoleum floor covering

It is recommended that resistance properties are measured for installed floors before use and regularly during use.

When the footwear/floor systems are used as the primary means of grounding personnel, it is recommended that either the resistance of the combination is maximum 35 Mohm or that the electrostatic potential is maximum 100 V (measured according to IEC 61340-4-5).

### Documentation for approval

Test report 5F015890, rev 1. The ESD-approval does not include any requirements regarding electrical safety properties. If work will be performed close to live voltages, requirements according to national regulations shall be obeyed.

### Conditions for approval

General conditions, according to SP-Method 2472, for approval and registration of approved products with regard to ESD-protection qualities.

### SP Technical Research Institute of Sweden Electronics – Product Safety

Anders Nilsson  
Technical Manager

Sven Byheden  
Technical Officer

### SP Technical Research Institute of Sweden

Postal address  
SP  
Box 857  
SE-501 15 Borås  
SWEDEN

Office location  
Västerås  
Brinellgatan 4  
SE-504 62 Borås  
SWEDEN

Phone / Fax / E-mail  
+46 10 516 50 00  
+46 33 13 55 02  
info@sp.se

This document may not be reproduced other than in full, except with the prior written approval of SP.