Cleanroom® Suitable Materials

TARKETT GDL S.A.
Report No. TA 1302-638

Protectwall 2CR
Particle (vs. PA6): ISO 1

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated below, provided by

TARKETT GDL S.A.
Wiltz, Luxembourg

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TA 1302-638.

Protectwall 2CR, batch number W2904324 was tested regarding particle emission during the application of frictional stress according to VDI 2083-17. The tested material obtained the following classification:

Material pairing and test		Suitable for Air Cleanliness Class (ISO 14644-1)
Protectwall 2CR	vs. PA6	ISO Class: 1
Reel-on-disc test Normal force 300 N		

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, June 15, 2013

i. A.
Project manager

Fraunhofer IPA

Cleanroom® Suitable Materials

TARKETT GDL S.A.
Rapport N° TA 1302-638

Protectwall 2CR
Particule (vs. PA6): ISO 1

Flooring & Coating

Certificat de qualification

Nous certifions par la présente que le matériau mentionné ci-dessous, fourni par

TARKETT GDL S.A.
Wiltz, Luxembourg

a obtenu le Certificat de Qualification de Fraunhofer IPA CSM comportant le numéro de rapport TA 1302-638.

Les tests sont réalisés selon VDI 2083-17 incluant l'émission de particules pendant l'application de forces de friction.
Protectwall 2CR, Numéro de lot: W2904324 a obtenu la classification suivante:

Appariement des matériaux et test	Classe de pureté de l'air (ISO 14644-1)
Protectwall 2CR vs. PA6 Méthode du disque tournant Force normale 300 N	ISO classe: 1

La validité de la présente attestation est illimitée dans le temps et se restreint au produit précité. Elle peut être vérifiée sous www.tested-device.com.

Pour plus d'informations sur CSM, veuillez visiter le site www.ipa-csm.com.

Des informations détaillées sur l'environnement du test et les paramètres utilisés peuvent être obtenues à partir du rapport de test CSM émis par la société Fraunhofer-Gesellschaft.

Stuttgart, Juin 15, 2013

i. A.
Directeur du projet

Fraunhofer IPA