LNE
Le progrès, une passion à partager
LABORATOIRE DE TRAPPES
29 avenue Roger Hennequin – 78197 Trappes Cedex
Tél. : 01 30 69 10 00 – Fax : 01 30 69 12 34

EUROPEAN REACTION TO FIRE CLASSIFICATION REPORT ACCORDING TO THE EUROPEAN STANDARD EN 13501-1

Notified Body by the French State besides the European Commission under number : 0071

Product standard : NF EN 14904
Specification for indoor surfaces for multi-sports use

(free translation of French classification report n° H061401 CEMATE/9)

N°H061401 - CEMATE/10

Material submitted by : FieldTurf Tarkett SAS
2 rue de l'Egalité
92748 NANTERRE Cedex
FRANCE

Commercial trademark : OMNISPORTS TRAINING

Brief description : Multilayers PVC multi-sports floorcovering

Date of report : 2007, September 17th

Only full reproduction of the present document is authorized.
It contains 4 pages

1. INTRODUCTION

This classification report defines the classification assigned to product in accordance with the procedures given in EN 13501-1.

2. DETAILS OF CLASSIFIED PRODUCT

2.1. NATURE AND END USE APPLICATION

Multi - sport floorcovering.

2.2. DESCRIPTION

Product characteristics:

Commercial trademark	Composition
OMNISPORTS TRAINING	Vinyl sports floor covering over fibreglass mat with PVC foam backing. Sanitized (anti-bacterial coating). Protected with Top clean XP (dirt-resistant treatment for ease of maintenance)

Density : 0.85

Mass per unit square area : 4,23 Kg/m²

Thickness : 5 mm

Colour :
Orange, red, grey, green forest, royal blue, field green, teal, sky blue, immitation classic oak and gunstock, beech, maple

Fire retardant : yes

Informations given by the sponsor

Text report to be followed on next page

3. TEST REPORTS AND TEST RESULTS IN SUPPORT OF THIS CLASSIFICATION

3.1. TEST REPORTS

Name of laboratory	Name of sponsor	Test report ref. n°	Test method
Laboratoire national de métrologie et d'essais 29 av. Roger Hennequin 78197 TRAPPES CEDEX	FieldTurf Tarkett SAS 2 rue de l'Egalité 92748 NANTERRE Cedex FRANCE	File : H061401 CEMATE/1 file : H061401 CEMATE/2	Ignitability NF EN ISO 11925-2 Radiant panel EN ISO 9239-1

3.2. TEST RESULTS FOR FLOORINGS

Test method	Number of tests	Parameters	**Results**
NF EN ISO 11925-2 15 s exposure	1 (6 specimens)	Flame spread ≤ 150 mm	**Yes**
NF EN ISO 9239-1	1 (3 specimens)	Critical flux (kW/m^2) Smoke (%.min)	**7,62** **295**

Text report to be followed on next page

4. CLASSIFICATION AND DIRECT FIELD APPLICATION

4.1. CLASSIFICATION

Fire behaviour	Smoke production	Flaming droplets
C_{fl}	s1	-

4.2. FIELD OF APPLICATION

This classification is valid for the products mentionned in § 2.2 or strictly and equally stipulated in the quoted production site.
Colour : various
Thickness : 5 mm
Vinyl sports floor covering glued with an acrylic adhesive with extension in stuck standing to classified A1fl or A2fl substrates.

5. LIMITATIONS

5.1. RESTRICTIONS CONCERNING THE VALIDITY PERIOD OF THE CLASSIFICATION REPORT

None.

5.2. WARNING

This document does not represent type approval or certification of the product.

Trappes, the 17th of September 2007

Director of the Centre for Energy, Materials and Packaging

Hervé MARCEL

Laboratoire national de métrologie et d'essais • LNE

Test officer

Luc CHEVALIER