

Handled by, department  
Marina C Andersson  
Fire Technology  
+46 10 516 52 92, marina.andersson@sp.se

Tarkett AB  
Box 3004  
372 81 RONNEBY

## Reaction to fire classification report

### 1 Introduction

This classification report defines the classification assigned to the product "iQ Granit SD" in accordance with the procedure given in EN 13501-1:2007.

### 2 Details of classified product

#### 2.1 General

The product "iQ Granit SD" is defined as a resilient floor covering. Its classification is valid for the end use application as floor covering for indoor use.

According to the owner of this classification report, this product complies with the European product specification EN 14041:2004.

#### 2.2 Product description

The product, "iQ Granit SD", is fully described below.

Homogeneous, dissipative vinyl flooring called "iQ Granit SD", consisting of with organic content consisting of polyvinylchloride, plasticizer, stabilizer and surface of PU-coating. The product has a nominal area weight of 3.0 kg/m<sup>2</sup>, a nominal density of 1.5 kg/m<sup>3</sup> and a nominal thickness of 2.0 mm.

### 3 Test reports & test results in support of classification

#### 3.1 Test reports

This classification is based on the test report listed below:

Name of laboratory	Name of sponsor	Test report ref no	Accredited test method
SP	Tarkett AB	P805041B	EN ISO 9239-1 EN ISO 11925-2

#### SP Technical Research Institute of Sweden

Postal address  
SP  
Box 857  
SE-501 15 Borås  
SWEDEN

Office location  
Västeråsen  
Brinellgatan 4  
SE-504 62 Borås  
SWEDEN

Phone / Fax / E-mail  
+46 10 516 50 00  
+46 33 13 55 02  
info@sp.se

Laboratories are accredited by the Swedish Board for Accreditation and Conformity Assessment (SWEDAC) under the terms of Swedish legislation. This report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

**3.2 Test results**

Test method	Parameter	Number of tests	Results	
			Continuous parameter mean (m)	Compliance parameter
EN ISO 11925-2 15 s exposure	$F_s \leq 150 \text{ mm}$	6	(-)	Compliant
EN ISO 9239-1	<i>Critical flux</i> (kW/m <sup>2</sup> )	4	9.8	Compliant
	<i>Smoke</i> (%.min)		263	Compliant

(-) : not applicable

**4 Classification and field of application**

**4.1 Reference and direct field of application**

This classification has been carried out in accordance with clause 12 and 15 of EN 13501-1:2007.

**4.2 Classification**

The product called “iQ Granit SD” in relation to its reaction to fire behaviour is classified:

$B_n$

The additional classification in relation to smoke production is:

s1

The format of the reaction to fire classification for floorings is:

Fire Behaviour		Smoke Production	
$B_n$	-	s	1

**Reaction to fire classification:  $B_{fl-s1}$**

#### 4.3 Field of application:

This classification is valid for the following product parameters:

Nominal thickness: 2.0 mm.

Nominal area weight: 3.0 kg/m<sup>2</sup>.

This classification is valid for the following end use applications:

Substrates

- Wood based substrates or substrates of Euroclass A1<sub>fl</sub> or A2<sub>fl</sub> having a density  $\geq 510$  kg/m<sup>3</sup>.

The sample was delivered by the client. SP Fire Technology was not involved in the sampling procedure.

#### 5 Limitations

This classification document does not represent type approval or certification of the product.

**SP Technical Research Institute of Sweden**  
**Fire Technology - Fire Dynamics**



Per Thureson  
Technical Manager



Marina C Andersson  
Technical Officer