

# Cleanroom<sup>®</sup> Suitable Materials

**Tarkett AB**  
**Report No. TA 1108-567**

**iQ Optima**  
**Particle (vs. PA6 Nylon): ISO 4**

## Flooring & Coating

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Tarkett AB**

372 73 Ronneby  
Sweden


has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TA 1108-567.

The tests performed in accordance with CSM procedures included particle emission during the application of frictional stress. The tested material obtained the following classification in accordance with the standard listed below.

Material (Mat.)	iQ Optima	
Particle	Reel-on-disc test; Normal force 300 N Mat. vs. PA6 Nylon	suitable for ISO Class 4 (see ISO 14644-1)

Detailed test information regarding the sample (serial number, color, batch number etc.), environment and parameters used, can be obtained from the CSM test report TA 1108-567 issued by the Fraunhofer-Gesellschaft.

Stuttgart, September 20, 2011

i. A.   
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified under [www.tested-device.com](http://www.tested-device.com)

For more CSM information please visit: [www.ipa-csm.com](http://www.ipa-csm.com)