Certificate

Tarkett Indoor Air Quality Platinum



Heterogene Compact

Products / Product Group

Tarkett France, 2 Avenue Francois Sommer, 08200 Sedan, France

Manufacturer

The products have undergone a successful testing and evaluation program as specified for Tarkett Indoor Air Quality Platinum certification version 4.0 (2018). This includes a chamber test of emissions and aldehydes and a surveillance of the manufacturing site according to DIN 18200, performed by Eurofins as independent third-party certifier and testing lab.

Evaluation of the results from emission testing and inspection:

- Formaldehyde was below or equal to the limit value of 10 μg/m³ after 28 days.
- Sum of VOC (TVOC) was below or equal to the limit values of 10 $\mu g/m^3$ after 28 days.
- V Sum of SVOC was below or equal to the limit value of 10 μg/m³ after 28 days.
- Quality management system and factory production control program at the production site are capable to ensure a continuous production of very low emitting products.
- \checkmark Therefore, the product qualifies for the Indoor Air Quality Tarkett Platinum label.

Certificate No.: TIAQP-30-04-04-2023

Date: 27 April 2023

Validity of certificate: 27 April 2028, with annual surveillance and retesting

Third-party certification and testing performed by:

Eurofins Certification Body VOC Am Neuländer Gewerbepark 4 21079 Hamburg, Germany

Head of the Certification Body

V. Neuraus

Sampling, testing and evaluation were performed according to the standards EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, EN 13419 each in the latest versions.

Certificate

Tarkett Indoor Air Quality Platinum



Appendix to Certificate TIAQP-30-04-04-2023

The manufacturer

Tarkett France

2, Avenue Francois Sommer 08200 Sedan France

receives the Certificate Tarkett Indoor Air Quality Platinum with validity 27 April 2028, with annual surveillance and retesting for the product group

Heterogene Compact

and the subgroups and individual products as listed below:

Acczent Essential 3/63 Acczent Platinium 3/90
Acczent Essential 4/70 Acczent Platinium 4/100
Acczent Excellence 3 MS Aquarelle / Aqua Multisafe

Acczent Excellence 4/80

Following certification, the manufacturer is authorized to use this certificate, this appendix to the certificate and the certification logo for any business documents, brochures, catalogues, delivery notes, offers, advertisements etc. in fairs and in the Internet in connection with the name of the manufacturer. When used with a specific product, the certificate number and validity shall be posted with the logo.

Third-party certification and testing performed by:

Eurofins Certification Body VOC Am Neuländer Gewerbepark 4 21079 Hamburg, Germany

Head of the Certification Body

V. Muraus

Sampling, testing and evaluation were performed according to the standards EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, EN 13419 each in the latest versions.