Certificate

Tarkett Indoor Air Quality Platinum



Tarkett Linoleum Flooring

Products / Product Group

Tarkett S.p.A., Via S. Anna 6, 05035 Narni Scalo, Italy

Manufacturer

The products have undergone a successful testing and evaluation program as specified for Tarkett Indoor Air Quality Platinum certification version 5.0 (2023). This includes a chamber test of emissions and aldehydes and a surveillance of the manufacturing site according to DIN 18200, performed by Eurofins as independent third-party certifier and testing lab.

Evaluation of the results from emission testing and inspection:

- Formaldehyde was below or equal to the limit value of 10 μg/m³ after 28 days.
- Sum of VOC (TVOC) was below or equal to the limit values of 10 $\mu g/m^3$ after 28 days.
- V Sum of SVOC was below or equal to the limit value of 10 μg/m³ after 28 days.
- ✓ Sum of Category 1A and 1B carcinogens was below or equal to the limit value of 0.001 mg/m³ after 28 days.
- Quality management system and factory production control program at the production site are capable to ensure a continuous production of very low emitting products.
- Therefore, the product qualifies for the Indoor Air Quality Tarkett Platinum label.

Certificate No.: TIAQP-30-01-08-2025A

Date: 10 June 2025

Validity of certificate: 10 January 2030, with annual surveillance and retesting

Third-party certification and testing performed by:

Eurofins Certification Body VOC Am Neuländer Gewerbepark 4 21079 Hamburg, Germany

V. Newhous

Head of the Certification Body

Sampling, testing and evaluation were performed according to the standards EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, EN 13419 each in the latest versions.

Certificate

Tarkett Indoor Air Quality Platinum



Appendix to Certificate TIAQP-30-01-08-2025A

The manufacturer

Tarkett S.p.A.Via S. Anna 6
05035 Narni Scalo

Italy

receives the Certificate Tarkett Indoor Air Quality Platinum with validity 10 January 2030, with annual surveillance and retesting for the product group

Tarkett Linoleum Flooring

and the subgroups and individual products as listed below:

Etrusco xf2 LinoTiles

Linoleum Bfl xf2 Originale xf2

Linoleum Conductive xf2 Sicuro R10 xf2

Linoleum SD Static Dissipative xf2 Style Elle xf2

LinoMarine Style Emme xf2

Lino Materiale Trentino xf2

LinoRail HL3 Veneto xf2

Linosport xf2

Following certification, the manufacturer is authorized to use this certificate, this appendix to the certificate and the certification logo for any business documents, brochures, catalogues, delivery notes, offers, advertisements etc. in fairs and in the Internet in connection with the name of the manufacturer. When used with a specific product, the certificate number and validity shall be posted with the logo.

Third-party certification and testing performed by:

Eurofins Certification Body VOC Am Neuländer Gewerbepark 4 21079 Hamburg, Germany

V. Newhous

Head of the Certification Body

Sampling, testing and evaluation were performed according to the standards EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, EN 13419 each in the latest versions.