

## Classification of reaction to fire in accordance with EN 13501-1

### 1 Introduction

This classification report defines the classification assigned to “Primo Premium” in accordance with the procedure given in EN 13501-1:2018.

### 2 Details of classified product

#### 2.1 General

The product “Primo Premium” is defined as floor covering.

According to the owner of this classification report, this product complies with the European product specification EN 14041:2004/AC:2006.

The sample was delivered by the client. RISE, Fire and Safety was not involved in the sampling procedure.

#### 2.2 Product description

The product, “Primo Premium”, is fully described below and in the test report provided in support of classification listed in Clause 3.1.

According to client:

Floor covering called “Primo Premium”, is a homogeneous vinyl flooring. The product has a nominal area weight of 3000 g/m<sup>2</sup>, a nominal density of 1575 kg/m<sup>3</sup> and a nominal thickness of 2.0 mm. The colour of the product is ocean blue.

#### RISE Research Institutes of Sweden AB

Postal address  
Box 857  
501 15 BORÅS  
SWEDEN

Office location  
Brinellgatan 4  
504 62 Borås  
SWEDEN

Phone / Fax / E-mail  
+46 10-516 50 00  
+46 33-13 55 02  
info@ri.se

Confidentiality level  
C3 - Sensitive

This report may not be reproduced other than in full, except with the prior written approval of RISE Research Institutes of Sweden AB.



Accred. No. 1002  
Certification of  
Products  
ISO/IEC 17065

### 3 Reports and results in support of this classification

#### 3.1 Test reports

Table 1 Test reports forming the basis for this classification.

| Name of laboratory | Name of sponsor | Test report reference no | Accredited test methods and date |
|--------------------|-----------------|--------------------------|----------------------------------|
| RISE               | Tarkett AB      | O100741-1259539-3        | EN ISO 9239-1:2010               |
| Efectis            | Tarkett AB      | EUI-24-SFB-000665D       | EN ISO 11925-2:2020              |

#### 3.2 Test results

Table 2 Test results showing the worst case as found in the test program performed.

| Test method    | Parameter                                 | Number of tests | Results | Continuous parameter mean (m) | Compliance parameter |
|----------------|-------------------------------------------|-----------------|---------|-------------------------------|----------------------|
| EN ISO 11925-2 |                                           | 6               |         |                               |                      |
| 15 s exposure  | $F_s \leq 150 \text{ mm}$                 |                 | (-)     |                               | Compliant            |
| EN ISO 9239-1  |                                           | 4               |         |                               |                      |
|                | <i>Critical flux</i> (kW/m <sup>2</sup> ) |                 | 10.0    |                               | Compliant            |
|                | <i>Smoke</i> (%.min)                      |                 | 122     |                               | Compliant            |

(-) : not applicable

### 4 Classification and field of application

#### 4.1 Reference of classification

This classification has been carried out in accordance with clause 12 and 15 of EN 13501-1:2018.

#### 4.2 Classification

The product called “Primo Premium” in relation to its reaction to fire behaviour is classified:

B<sub>fl</sub>

The additional classification in relation to smoke production is:

s1

The format of the reaction to fire classification for floorings is:

| Fire Behaviour        |   | Smoke Production |          |
|-----------------------|---|------------------|----------|
| <b>B<sub>fl</sub></b> | - | <b>s</b>         | <b>1</b> |

**Reaction to fire classification: *B<sub>fl</sub>-s1***

#### 4.3 Field of application:

This classification is valid for the following product parameters:

Product description, as specified in 2.2 in this report.

Nominal thickness: 2 mm.

Nominal density: 1575 kg/m<sup>3</sup>.

Nominal area weight: 3000 g/m<sup>2</sup>.

This classification is valid for the following end use applications:

Substrates

- Wood based substrates at least 18 mm thick or substrates of Euroclass A1 or A2-s1,d0 at least 6 mm thick, having a density  $\geq 510$  kg/m<sup>3</sup>.

Fixings

- With or without adhesive.

## 5 Limitations

This classification document does not represent type approval or certification of the product.

The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 of AVCP and CE marking under the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 laying down harmonised conditions for the marketing of construction products.

The manufacturer has made a declaration, which is held on file. This confirms that the products design requires no specific processes, procedures or stages (e.g. no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested.

### **RISE Research Institutes of Sweden AB** **Fire and safety - Reaction to Fire Medium Scale Lab**

Performed by



Susanne Blomqvist

Examined by



Richard Johansson

# Verification

Transaction 09222115557532951635

## Document

O100741-1259539-9 Tarkett AB EN 13501-1 Primo  
Premium  
Main document  
4 pages  
*Initiated on 2024-11-29 10:56:01 CET (+0100) by Susanne  
Blomqvist (SB)*  
*Finalised on 2024-11-29 13:31:06 CET (+0100)*

## Signatories

Susanne Blomqvist (SB)  
RISE Research Institutes of Sweden AB  
Company reg. no. 556464-6874  
*susanne.blomqvist@ri.se*  
+46 10 516 50 84



*Signed 2024-11-29 11:01:05 CET (+0100)*

Richard Johansson (RJ)  
RISE Research Institutes of Sweden AB  
*richard.johansson@ri.se*



*Signed 2024-11-29 13:31:06 CET (+0100)*

This verification was issued by Scrive. Information in italics has been safely verified by Scrive. For more information/evidence about this document see the concealed attachments. Use a PDF-reader such as Adobe Reader that can show concealed attachments to view the attachments. Please observe that if the document is printed, the integrity of such printed copy cannot be verified as per the below and that a basic print-out lacks the contents of the concealed attachments. The digital signature (electronic seal) ensures that the integrity of this document, including the concealed attachments, can be proven mathematically and independently of Scrive. For your convenience Scrive also provides a service that enables you to automatically verify the document's integrity at: <https://scrive.com/verify>

